

Energy Consumption and Greenhouse Gas Emissions Reporting - for 2017

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2017 - Dec/2017
Sector	Acute Hospital
Agency Sub-sector	Public Hospital
Organization Name	Toronto Hospital for Sick Children

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity
Stephenson Building	Administrative offices and related facilities	2160 Yonge Street	Toronto	M7A 2G5	135,034.00	Square feet	70	2,181,065.00000	kWh	125,300.00000	Cubic meter	110,000.00000
Annex	Administrative offices and related facilities	555 University Ave	Toronto	M5G 1X8	96,155.00	Square meter:	168	15,457,770.00000	kWh	4,320.00000	Cubic Meter	
Atrium	Facilities used for hospital purposes	170 Elizabeth St	Toronto	M5G 1X8	952,980.00	Square feet	168	24,189,420.00000	kWh			
McMaster	Facilities used for hospital purposes	175 Elizabeth St	Toronto	M5G 2G3	198,305.20	Square feet	168	1,141,352.00000	kWh	12,330.00000	Cubic Meter	
Peter Gilgan Centre for Research	Facilities used for hospital purposes	686 Bay St	Toronto	M5G 0A4	852,746.00	Square feet	168	30,848,620.00000	kWh	4,163.00000	Cubic Meter	

Energy Consumption and
Confirm consecutive 12-mth period (mth-yr to mth-yr)
Sector
Agency Sub-sector
Organization Name

Operation Name	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?
Stephenson Building	Litre	23,000.00235	Litre		Litre		Metric Tonne		Metric Tonne	26.73000	Giga Joule	No
Annex										86,961.14000	Giga Joule	No
Atrium										80,710.87000	Giga Joule	No
McMaster										2,389.22000	Giga Joule	No
Peter Gilgan Centre for Research										134,615.30000	Giga Joule	No

Energy Consumption and
Confirm consecutive 12-mth period (mth-yr to mth-yr)
Sector
Agency Sub-sector
Organization Name

Operation Name	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Building / Operation Identifier	Comments
Stephenson Building	0.00000	20.50600	KL Chilled Water	No	0.00000				max. 255 characters
Annex	0.00000					5,432,202.32121	38.31825		
Atrium	0.00000					5,204,444.61374	48.90880		
McMaster	0.00000					184,731.18199	9.76306		
Peter Gilgan Centre for Research	0.00000					8,523,946.29141	80.07778		